

INSTALLER SUPPLIED LOW VOLTAGE TERMINALS (24V NOMINAL)


SELECT LOW OR LINE VOLTAGE INCOMING POWER TO SCC, NOT BOTH

RELAY CONTROL WIRING TERMINALS. CONNECT TO COM & N/C. DO NOT USE SOLID CORE WIRE

INSTALLER SUPPLIED OPTIONAL LINE VOLTAGE (90-240 VAC, 50-60 HZ)

NO INTERNAL SENSOR

INTERNAL CATALYTIC H<sub>2</sub> SENSOR.  
ESH-A WITH H<sub>2</sub> SENSOR SHOULD BE INSTALLED ON OR NEAR THE CEILING.



ESH-A 4-WIRE ANALOG TRANSMITTER WIRED TO SCC SELF-CONTAINED SYSTEM

THIS SCC-B-R / ESH-A COMBINATION MAKES A ONE CHANNEL H<sub>2</sub> DETECTION SYSTEM MONITORING HYDROGEN IN BATTERY CHARGING ROOMS.

**CRITICAL ENVIRONMENT TECHNOLOGIES CANADA INC.**  
www.critical-environment.com  
  
SCC-B-R WITH ESH-A-CH2 WIRING CONNECTION PHOTO DRAWING  
March 28, 2016