



## **Critical Environment Technologies**

Unit 145, 7391 Vantage Way Delta, BC, Canada V4G 1M3

phone 604-940-8741 fax 604-940-8745

www.critical-environment.com

### **ENGINEERING SPECIFICATION SAMPLE # DST-2**

## **Carbon Monoxide & Nitrogen Dioxide Transmitters for Parking Garages**

Provide digital transmitters with continuous, linear, signal capable of being connected to a PDC controller on a RS-485 communication bus. The transmitters shall be a CET model DST-MCO for Carbon Monoxide and a model DST-END for Nitrogen Dioxide. The transmitters shall provide a digital signal representing the Nitrogen Dioxide detection range of 0 - 10 ppm and the Carbon Monoxide detection range of 0 - 200 ppm. All transmitters shall incorporate accurate electrochemical sensors and automatic resetting thermal fuse for fault protection. The transmitters shall be installed 4' - 6' from the floor (breathing zone) and each unit shall be capable of monitoring an area of approximately 5000 to 7500 SF.

The transmitter circuit shall be housed in a wall mount, rugged, break resistant, corrosion resistant, PVC junction box with a secured, hinged door. The PVC junction box shall have conduit entry ports on the top, bottom, right side and rear. The circuit shall operate from 24 VDC input voltage supplied from the controller. Wiring shall be 2 conductors for low voltage power, and a two wire shielded twisted pair for the communication bus. Wiring shall be shielded or in conduit. An optional watertight Polycarbonate enclosure shall be available.

System operation shall be as follows: Upon detection of 0.7 ppm NO<sub>2</sub> or 25 ppm CO, the controller shall activate exhaust fans. Upon detection of 1.5 ppm NO<sub>2</sub> or 100 ppm CO, the controller shall activate audible and visual alarms.

Contractor shall provide all wiring, conduit and interconnection required for a successful installation.

#### **Approved manufacturer:**

Critical Environment Technologies