



Listing on BACnet International website

BACnet Protocol Implementation Conformance Statement

Date: June 2016

Vendor Name: Critical Environment Technologies Canada Inc.

Product Name: CETCI BACnet Module for QCC-B, FCS-B, LPT-P-B and LPT-B

Product Model Numbers: QCC-B, FCS-B, LPT-P-B, LPT-B

Application Software Version: 1.12 Firmware Revision: 1.00.81 BACnet Protocol Version/Revision: 14

Product Description:

The CETCI BACnet Module is a microprocessor intended to plug into CETCI's QCC or FCS controllers or LPT-P-B or LPT-B gas detectors to facilitate BACnet communications between the device and a building automation system commonly used in HVACr applications.

BACnet Standardized Device Profile (Annex L):

- BACnet Operator Workstation (B-OWS)
BACnet Building Controller (B-BC)
BACnet Advanced Application Controller (B-AAC)
BACnet Application Specific Controller (B-ASC)
BACnet Smart Sensor (B-SS)
BACnet Smart Actuator (B-SA)

List all BACnet Interoperability Building Blocks Supported (Annex K):

Table with 4 columns: BIBB, Service, Initiates, Responds to. Rows include DS-RP-B, DS-WP-B, DM-DDB-B, DM-DOB-B, DM-DCC-B, DM-RD-B.

Segmentation Capability:

Segmented requests supported Window Size 480
Segmented responses supported Window Size 480

Standard Object Types Supported:

An object type is supported if it may be present in the device. For each standard Object Type supported provide the following data:

- 1) Whether objects of this type are dynamically creatable using the CreateObject service
- 2) Whether objects of this type are dynamically deletable using the DeleteObject service
- 3) List of the optional properties supported
- 4) List of all properties that are writable where not otherwise required by this standard
- 5) List of proprietary properties and for each its property identifier, datatype, and meaning
- 6) List of any property range restrictions

Note: none of the object types listed in this section is dynamically creatable or dynamically deletable.

Note: the BACnet conformance codes are as follows:

- O - Optional (may be required under some conditions)
- R - Required, but not required to be writable (may be required to be writable under some conditions)
- W - Not only required, but also required to be writable

The following codes are used in this document to describe how the properties are implemented:

- R/W - Read/write
- R/O - Read-only
- R/O=value - Implemented as a read-only with the indicated value

Device Object

Property	BACnet Conf Code	Implementation
Object_Identifier	R	R/W
Object_Name	R	R/W
Object_Type	R	R/O="device"
System_Status	R	R/O="operational"
Vendor_Name	R	R/O
Vendor_Identifier	R	R/O
Model_Name	R	R/O
Firmware_Revision	R	R/O
Application_Software_Version	R	R/O
Location	O	R/W
Description	O	R/W
Protocol_Version	R	R/O=1
Protocol_Revision	R	R/O=14
Protocol_Services_Supported	R	R/O
Protocol_Object_Types_Supported	R	R/O
Object_List	R	R/O



Max_APDU_Length_Accepted	R	R/O=480
Segmentation_Supported	R	R/O="none"
Local_Time	O	R/O
Local_Date	O	R/O
UTC_Offset	O	R/W
Daylight_Savings_Status	O	R/O
APDU_Timeout	R	R/W=7000
Number_Of_APDU_Retries	R	R/W=1
Max_Master	O	R/O=127
Device_Address_Binding	R	R/O=empty list
Data_Base_Revision	R	R/O
Max_Info_Frames	O	R/O =1

Analog Input

Property	BACnet Conf Code	Implementation
Object_Identifier	R	R/O
Object_Name	R	R/O
Object_Type	R	R/O="analog-input"
Present_Value	R	R/O
Status_Flags	R	R/O
Event_State	R	R/O="normal"
Out_Of_Service	R	R/O=FALSE
Units	R	R/O
Property_List	R	R/O

Analog Output

Property	BACnet Conf Code	Implementation
Object_Identifier	R	R/O
Object_Name	R	R/O
Object_Type	R	R/O="analog-output"
Present_Value	W	R/W
Status_Flags	R	R/O="all normal"
Event_State	R	R/O="normal"
Out_Of_Service	R	R/O=FALSE
Units	R	R/O
Priority_Array	R	R/O
Relinquish_Default	R	R/W
Property_List	R	R/O

Binary Input

Property	BACnet Conf Code	Implementation
----------	------------------	----------------



Object_Identifier	R	R/O
Object_Name	R	R/O
Object_Type	R	R/O="binary-input"
Present_Value	R	R/O
Status_Flags	R	R/O="all normal"
Event_State	R	R/O="normal"
Out_Of_Service	R	R/O=FALSE
Polarity	R	R/O
Property_List	R	R/O

Binary Output

Property	BACnet Conf Code	Implementation
Object_Identifier	R	R/O
Object_Name	R	R/O
Object_Type	R	R/O="binary-output"
Present_Value	W	R/W
Status_Flags	R	R/O="all normal"
Event_State	R	R/O="normal"
Out_Of_Service	R	R/O=FALSE
Polarity	R	R/O
Priority_Array	R	R/O
Relinquish_Default	R	R/W

Data Link Layer Options:

- BACnet IP, (Annex J)
- BACnet IP, (Annex J), Foreign Device
- ISO 8802-3, Ethernet (Clause 7)
- ANSI/ATA 878.1, 2.5 Mb. ARCNET (Clause 8)
- ANSI/ATA 878.1, RS-485 ARCNET (Clause 8), baud rate(s) _____
- MS/TP Master Node (Clause 9), baud rate(s): 9600, 19200, 38400, 57600, 76800, 115200
- MS/TP Slave (Clause 9), baud rate(s): _____
- Point-To-Point, EIA 232 (Clause 10), baud rate(s): _____
- Point-To-Point, modem, (Clause 10), baud rate(s): _____
- LonTalk, (Clause 11), medium: _____
- Other: _____

Device Address Binding:



Is static device binding supported? (This is currently necessary for two-way communication with MS/TP slaves and certain other devices.) Yes No

Networking Options:

- Router, Clause 6 - List all routing configurations, e.g., ARCNET-Ethernet, Ethernet-MS/TP, etc.
- Annex H, BACnet Tunneling Router over IP
- BACnet/IP Broadcast Management Device (BBMD)
 - Does the BBMD support registrations by Foreign Devices? Yes No

Character Sets Supported:

Indicating support for multiple character sets does not imply that they can all be supported simultaneously.

- ANSI X3.4
- IBM™/Microsoft™ DBCS
- ISO 8859-1
- ISO 10646 (UTF-8)
- ISO 10646 (UCS-2)
- ISO 10646 (UCS-4)
- JIS C 6226

If this product is a communication gateway, describe the types of non-BACnet equipment/networks(s) that the gateway supports:

Network Security Options:

- Non-secure Device - is capable of operating without BACnet Network Security